



Certificate No. : T-0071

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



## TEST REPORT

SHEET : 1 of 5

<b>NAME &amp; ADDRESS OF CUSTOMER</b>  COMFORT INSTA-POWER LTD. PLOT NO. 275-276, GIDC ESTATE, ANJAR-KUTCH, GUJARAT-INDIA	<b>REPORT NO. : HCCT/03/173</b> <b>DATE : 18.05.2010</b>	
	<b>CUSTOMER REF. NO.</b>	<b>DATE</b>
	CIPL/Gen/09-10/225	06.03.2010
	<b>DATE OF SAMPLE RECEIPT</b>	<b>DATE OF TESTING</b>
	06.03.2010	19.03.2010
<b>SAMPLE DESCRIPTION</b>  <b>DISTRIBUTION TRANSFORMER</b> MFG.BY : COMFORT INSTA-POWER LTD. RATING : 500 KVA VOLTS : 11000/433 V (at no-load) CURRENT : 26.24/667.00 Amps. PHASES : 3/3 FREQUENCY : 50 Hz WINDING : Copper % IMPEDANCE : 4.75 % VECTOR GROUP : Dyn 11 GUAR. MAX. TEMP. RISE IN OIL: 50 °C	<b>SAMPLE IDENTIFICATION</b>  ERDA ID NO. : HCCT-1450 MFG.SR NO. : IP-95 COOLING : ONAN CUSTOMER : KHUSBOO ISPAT (P) LTD.	
	<b>TEST DETAILS</b> As per sheet 2 of 5.	
<b>TEST SPECIFICATION</b> As per customer's requirement & test Procedure followed as per IS:2026-1977 & 1981.		
<b>TEST RESULTS :</b> As per sheet 2 of 5 to 5 of 5.		
<b>REMARKS :</b> Transformer <b>conforms</b> to the guaranteed requirement as per above mentioned test specification for above mentioned tests.		
 <b>PREPARED BY</b>	 <b>CHECKED BY</b>	 <b>APPROVED BY</b>
<b>Note :</b> 1. This report relates only to the particular sample received in good condition for testing at E.R.D.A. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, E.R.D.A. 4. Only the tests asked for by the customer have been carried out.		



TE 0417470



Certificate No. : T-0071

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



**REPORT NO.:** HCCT/03/173

**SHEET :** 2 of 5

**DATE :** 18.05.2010

## TEST DETAILS :

SR. NO.	TESTS	CLAUSE NO.
1.	Measurement of winding resistance	16.2, IS: 2026 - 1977, Part-I
2.	Measurement of voltage ratio and check of voltage vector relationship	16.3, IS: 2026 - 1977, Part-I
3.	Measurement of impedance voltage and Load loss	Customer's requirement and cl. no.16.4, IS: 2026-1977, Part-I
4.	Measurement of no load loss and current	Customer's requirement and cl.no.16.5 of IS:2026-1977, Part-I
5.	Measurement of Insulation resistance	16.6, IS: 2026 - 1977, Part-I
6.	Dielectric tests - Induced over voltage test - Separate source voltage withstand test on HV and LV winding	11.0, IS: 2026 - 1981, Part-III 10.0, IS: 2026 - 1981, Part-III

**PREPARED BY**

**CHECKED BY**



TE 0417471





Certificate No. : T-0071

# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org



Web : http://www.erda.org



**REPORT NO.:** HCCT/03/173

**DATE** : 18.05.2010

**SHEET : 3 of 5**

Sr. No.	Particulars of Tests	Requirement	Obtained Value	Remarks
1.	<b>Measurement of winding resistance</b> (As per cl.no.16.2, IS: 2026 - 1977, Part-I) At top oil temp: 34.0 °C  <b>HV Winding</b> 1U - 1V : -- 3.4298 Ω 1V - 1W : -- 3.4350 Ω 1U - 1W : -- 3.4198 Ω <b>Average</b> : -- 3.4282 Ω  <b>LV Winding</b> 2U - 2V : -- 4.4664 mΩ 2V - 2W : -- 4.4638 mΩ 2U - 2W : -- 4.5280 mΩ <b>Average</b> : -- 4.4861 mΩ			
2.	<b>Measurement of voltage ratio and check of voltage vector relationship :</b> (As per cl. no.16.3 of IS:2026 - 1977,Pt.I) <b>Voltage ratio measured between</b> 1U-1V and 2u-2n: 44.00 ± 0.5%  1V-1W and 2v-2n: 44.00 ± 0.5%  1W-1U and 2w-2n: 44.00 ± 0.5%  <b>Vector Group :</b> Dyn11	44.00 ± 0.5%  44.00 ± 0.5%  44.00 ± 0.5%  Dyn11	44.016  44.046  43.982  Dyn11	Conforms
<div> <div>  </div> <div>  </div> </div> <div> <div>PREPARED BY</div> <div>CHECKED BY</div> </div>				



TE 0417617



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33.

Fax : +91 (0265) 2638382

E-mail : [erda@erda.org](mailto:erda@erda.org)


Web : <http://www.erda.org>




**SHEET : 4 of 5**

DATE :18.05.2010


Sr. No.	Particulars of Tests	Requirement	Obtained Value	Remarks
3.	<b>Measurement of impedance voltage and Load loss :</b> (As per customer's requirement, Testing procedure followed as per cl.no.16.4 of IS:2026-1977,Part-I.) Tested with <b>26.300</b> Amps. ( on HV side ) Frequency : <b>49.427</b> Hz Top oil temp.: <b>35.4 °C</b>  <div style="text-align: right;"><b>Test current</b> (in Amps.)</div> <div style="text-align: right;"><b>Impedance voltage</b> (Volts)</div> <div style="text-align: right;"><b>Measured load loss</b> (Watts)</div> <div style="text-align: right;"> <b>Load loss</b> (Watts)  (Computed to 100% load)  At 35.4 °C   At 75 °C   <b>Impedance voltage</b> (%)  (Computed to 100% load)  At 35.4 °C   At 75 °C </div>		26.300         498.17         7144.56         7128.16         8022.02         4.52         4.63	Conforms
4.	<b>Measurement of no load loss and current :</b> (As per customer's requirement, Testing procedure followed as per cl.no.16.5 of IS:2026-1977,Part-I.) Tested with average <b>434.66</b> Volts. ( on LV side ) Frequency : <b>50.169</b> Hz  <div style="text-align: right;"><b>RMS Voltage</b> (Volts)</div> <div style="text-align: right;"><b>No load current</b>(in Amps.)</div> <div style="text-align: right;"><b>Measured No load loss</b> (Watts)</div> <div style="text-align: right;"><b>Corrected No load loss</b> (Watts)</div>		442.42         13.54         1043.50         1025.05	Conforms



**PREPARED BY**



**CHECKED BY**



TE 0417473







Certificate No.: T-0071

# **ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



**REPORT NO.:** HCCT/03/173

**SHEET:** 5 of 5

**DATE** : 18.05.2010

Sr. No.	Particulars of Tests	Requirement	Obtained Value	Remarks
5.	<b>Measurement of Insulation Resistance</b> : (As per cl.no.16.6 of IS:2026-1977,Part.I) Top oil temp.: 32.0 °C <b>IR value measured between</b> HV winding --- Earth at 2500 V DC LV winding --- Earth at 500 V DC HV winding --- LV winding at 2500 V DC		20.5 GΩ 10.5 GΩ 18.0 GΩ	
6.	<b>Dielectric tests :</b> (As per cl no.16.7 of IS:2026 – 1977,Part.I) <b>- Induced over voltage test :</b> (As per cl.no. 11.0 of IS:2026 – 1981,Pt. III ) test voltage of 866 Volts, 3 – phase was applied to the LV winding of the transformer. The supply frequency was maintained at 100 Hz. The test voltage was applied for 60 seconds.	Sample shall withstand 866 volts at 100 Hz frequency for 60 seconds	Withstood	<b>Conforms</b>
	<b>- Separate source power frequency voltage withstand test on HV winding:</b> (As per cl.no.10.0 of IS : 2026 – 1981, Part. III ) The test voltage of 28 kV ac, rms was applied between the HV winding and earth. The tank and LV winding were shorted together and earthed. The test voltage was applied for 60 seconds.	Sample shall withstand power frequency voltage of 28 KV for 60seconds.	Withstood	<b>Conforms</b>
	<b>- Separate source power frequency voltage withstand test on LV winding:</b> (As per cl.no.10.0 of IS : 2026 – 1981, Part. III ) The test voltage of 3 kV ac, rms was applied between the LV winding and earth. The tank and HV winding were shorted together and earthed. The test voltage was applied for 60 seconds.	Sample shall withstand power frequency voltage of 3KV for 60seconds	Withstood	<b>Conforms</b>

**PREPARED BY**

**CHECKED BY**



TE 0417474